

PLANT OPERATIONS—RAVENSWOOD

Safety

No injuries MTD or YTD

Maintenance

- Purchase order placed for additional security services from Alcan
- # 1 blocking deep well pump in pump house installation complete. Well needs cleaned out.
- GM Baker is in the process of testing #7 deep well. This well is our back up domestic water well.
- Work on Diesel portable air compressor for use in the plant is complete
- Installed new exhaust fan in chlorine room at pump house
- In the process of repairing 4" trash pump used to pump out electrical manholes
- Doeffinger attended Board meeting of the Mid Ohio Valley Chapter of the SMRP
- Removed North Bio Disc gearbox for repairs
- Gather up material for next week boiler outage and repairs to Alcan condensate return line
- Installed new trailer jack on Portable diesel air compressor
- Had all employees re-entered on hand scanner system
- Continue to make rounds throughout plant – checking for problems
- Continue daily checks of nitrogen blankets on Rectifier transformers
- Weekly PM of fire system air compressors
- Weekly check of oil skimmer
- Tore down Bio Disk gearbox
- Checked rectifier at Sow Casting
- Took Boiler outage March 31 thru April 2 to repair broken condensate return line