

PLANT OPERATIONS—RAVENSWOOD

No injuries YTD

Maintenance

- Working on cleaning out South Clarifier.
- Replaced a 4" valve to South Clarifier.
- PMed weed sprayer pump and engine.
- Changed blades on Cub Cadet.
- Straightened and sharpened blades on 72" bush hog mower.
- Repaired flat on Kubota mower.
- Installed disc mower on tractor.
- Started pumping electrical manholes.
- Fired up # 1 boiler after Alcan outage.
- Troubleshooting plant Fire supervisory panels for indicated ground.
- Tri State Roofing repaired two bad leaks in the Potroom offices
- Repaired bad front tire on MF tractor.
- Checked water conductivity on X-Ray spectrograph.
- Rebuild of North Bio Disc gearbox complete – Needs installed.
- Work on cleaning out South Clarifier complete.
- Continued pumping electrical manholes.
- Found bad card in Bake Carbon Fire supervisory panel. Card ordered.
- Replaced outdoor alarm horn at Boiler House.
- Lowered low-level alarm on boiler feed water tank to prevent water hammer.
- Replace bad trailer jack on trash pump cart.
- Making rounds throughout plant to check for problems.
- Continues daily checks of nitrogen blankets on Rectifier transformers.
- Weekly PM of fire system air compressors.
- Weekly check of oil skimmer.